



April 7, 2021

To: Genoa Township Zoning Commission
From: Anthony Caito, Fire Marshal
RE: 7562 Lewis Center Road additional access

Mr. Shaffer,

Pursuant to the Ohio Fire Code Section 503.1.2, the fire department is requiring an additional access for 7562 Lewis Center Road.

(b) 503.1.2 Additional access. The fire code official is authorized to require more than one fire apparatus access road based on the potential for impairment of a single road by vehicle congestion, condition of terrain, climatic conditions or other factors that could limit access.

Currently, the existing property is served by a single entry and exit driveway. Our concern is that the additional traffic in this area would hinder our response in the time of an emergency. Thus, we agree with the originally proposed access road that would intersect with Worthington Road. We have no opinion of where the access roadway would intersect on to Worthington Road.

Sincerely,

Anthony Caito
Fire Marshal